

## VERIFICATION OF LVD COMPLIANCE

No.: LVD GZES1308007483HS

Applicant: GD Midea Air-conditioning Equipment Co., Ltd.  
Midea Industrial City, Beijiao, Shunde, Foshan, Guangdong,  
China

Manufacturer: Same as applicant

Product Name: Multi Split-Type Air-Conditioner

Model No.: Refer to following pages

Rating: Refer to following pages

Protection against Electric Shock: Class I

Degree of Protection: IP24 for outdoor units

Additional Information (if any): Refrigerant: R410A

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-2-40: 2003 + A11: 2004 + A12: 2005 +  
A1: 2006 + A2: 2009 + A13: 2012  
EN 60335-1: 2012  
EN 62233: 2008

as shown in the

Test Report Number(s): GZES130800748301

This Verification of LVD Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Low Voltage Directive 2006/95/EC. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

  
Anson Luo  
Laboratory Manager  
SGS-CSTC



2013-11-01

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.: LVD GZES1308007483HS

Other information added:

**Model No. / Rating:**

Unit	Model	Rated voltage	Rated power (W)	Rated current (A)	
Outdoor unit	M2OD-18HFN1-Q	220-240 V; 50 Hz	3200	14,5	
	M3OD-27HFN1-Q		3600	16,5	
	M4OA-36HFN1-Q		4800	21,5	
Indoor unit	MS11MU series	220-240 V; 50 Hz	MS11MI-07HRFN1-QW	24	0,11
			MS11MU-09HRFN1-QRD0W	24	0,11
			MS11MU-12HRFN1-QRD0W	24	0,11
			MS11MU-12HRFN1-QRD0W(B)	24	0,11
			MS11MU-18HRFN1-QRC8W	62	0,28
	MS11PU series	220-240 V; 50 Hz	MS11PU-09HRFN1-QRD0W	24	0,11
			MS11PU-12HRFN1-QRC8W	24	0,11
			MS11P1U-12HRFN1-QRD0W	24	0,11
			MS11PU-18HRFN1-QW	24	0,11

Anson Luo  
Laboratory Manager  
SGS-CSTC



2013-11-01

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES1308007483HS

Other information added:

**Model No. / Rating:**

Unit	Model	Rated voltage	Rated power (W)	Rated current (A)	
Outdoor unit	M2OD-18HFN1-Q	220-240 V; 50 Hz	3200	14,5	
	M3OD-27HFN1-Q		3600	16,5	
	M4OA-36HFN1-Q		4800	21,5	
Indoor unit	MS9AU series	220-240 V; 50 Hz	MS9AU-09HRDN1-QRC8W	45	0,2
			MS9AU-12HRDN1-QRC8W	45	0,2
			MS9AU-18HRFN1-QRC8W	34	0,14
	MS9AI series	220-240 V; 50 Hz	MS9AI-07HRFN1-QRC8	24	0,11
			MS9AI-07HRFN1-Q	24	0,11
			MS9AI-09HRDN1-QRC8	45	0,2
	MTBI series	220-240 V; 50 Hz	MTBI-07HRFN1-Q	30	0,1
			MTBI-09HRFN1-Q	30	0,1
			MTBI-12HRFN1-Q	40	0,13
			MTBI-18HWDN1-Q	107	0,48
	MCA2I series	220-240 V; 50 Hz	MCA2I-07HRFN1-Q	15	0,06
			MCA2I-09HRFN1-Q	15	0,06
			MCA2I-12HRFN1-Q	20	0,08
MCA2I-18HRDN1			102	0,44	

Anson Luo  
 Laboratory Manager  
 SGS-CSTC



2013-11-01

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES1308007483HS

Other information added:

**Model No. / Rating:**

Unit	Model	Rated voltage	Rated power (W)	Rated current (A)	
Outdoor unit	M2OD-14HFN1-Q	220-240 V; 50 Hz	2400	11,0	
	M3OD-21HFN1-Q		3300	15,0	
	M4OD-28HFN1-Q		3700	17,0	
	M5OC-36HFN1-Q		4900	22,0	
Indoor unit	Wall mounted type	220-240 V; 50 Hz	MS12FI-07HRDN1-QRC8W	48	0,21
			MS12FU-09HRDN1-QRC8W	48	0,21
			MS12FU-12HRFN1-QRC8W	24	0,11
			MS12FU-18HRFN1-QRC8W	34	0,14
			MS11M-18HRFN1-QRC8Q1W	62	0,28
	Four-way cassette type	220-240 V; 50 Hz	MCA2I-07HRFN1-QRC8	40	0,18
			MCA2I-09HRFN1-QRC8	40	0,18
			MCA2U-12HRFN1-QRC8	40	0,18
			MCA2I-18HRDN1-QRC8	102	0,44
	Ducted type	220-240 V; 50 Hz	MTBI-07HWFN1-QRC8	30	0,13
			MTBI-09HWFN1-QRC8	30	0,13
			MTBU-12HWFN1-QRC8	40	0,17
			MTBI-18HWDN1-QRC8	107	0,48
	Floor-standing type	220-240 V; 50 Hz	MFAI-07HRFN1-QRC8	30	0,13
			MFAI-09HRFN1-QRC8	30	0,13
			MFAU-12HRFN1-QRC8	40	0,17
MFAI-18HRFN1-QRC8			50	0,22	

Anson Luo  
 Laboratory Manager  
 SGS-CSTC



2013-11-01

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)