



Ref. Certif. No.

SG-HS-01360

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**
CERTIFICAT D'ESSAI OC

Product

Produit

Name and address of the applicant

Nom et adresse du demandeur

Name and address of the manufacturer

Nom et adresse du fabricant

Name and address of the factory

Nom et adresse de l'usine

Rating and principal characteristics

Valeurs nominales et caractéristiques principales

Trade mark (if any)

Marque de fabrique (si elle existe)

Model/type Ref.

Ref. de type

Additional information (if necessary)

Information complémentaire (si nécessaire)

A sample of the product was tested and found
to be in conformity withUn échantillon de ce produit a été essayé et a été
considéré conforme à la

as shown in the Test Report Ref. No.

which form part of this certificate

comme indiqué dans le Rapport d'essais numéro
de référence qui constitue une partie de ce
certificat

Air conditioning equipment

(HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER)

GD Midea Air-Conditioning Equipment Co., Ltd.

Midea Industrial City, Beijiao,

528311 Shunde, Foshan, Guangdong, PEOPLE'S REPUBLIC OF
CHINAGD Midea Air-Conditioning Equipment Co., Ltd., Midea Industrial
City, Beijiao., 528311 Shunde, Foshan, Guangdong, PEOPLE'S
REPUBLIC OF CHINAGD Midea Air-Conditioning Equipment Co., Ltd., Midea Industrial
City, Beijiao., 528311 Shunde, Foshan, Guangdong, PEOPLE'S
REPUBLIC OF CHINA

Rated voltage: 220-240 V

Rated frequency: 50 Hz

Rated input: see page 2

Protection class: I

Degree of protection: IPX0 (indoor side)

IP24 (outdoor side)

Refrigerant: R410A

Midea

MHD-24HRDN1-Q/MOU-24HDN1-Q,

MHD-30HRDN1-Q/MOU-30HDN1-Q,

MHD-36HRDN1-Q/MOU-36HDN1-Q,

MHD-42HRDN1-Q/MOU-42HDN1-Q

IEC 60335-1/A2:2006

IEC 60335-2-40/A2:2005

TÜV SÜD PSB Pte Ltd

085-10118901-000

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Date,

2010-08-30

CBS 10 08 54647 828

(Darius Guo)



TÜV SÜD PSB Pte Ltd · 1 Science Park Drive · Singapore 118221

PSB Singapore



Ref. Certif. No.

SG-HS-01360

Model	Indoor model	Outdoor model	Indoor unit		Outdoor unit	
			Rated power input	Rated current	Rated power input	Rated current
MHD-24HRDN1-Q/MOU-24HDN1-Q	MHD-24HRDN1-Q	MOU-24HDN1-Q	300W	1,3A	3800W	19,0A
MHD-30HRDN1-Q/MOU-30HDN1-Q	MHD-30HRDN1-Q	MOU-30HDN1-Q	700W	3,0A	4800W	22,0A
MHD-36HRDN1-Q/MOU-36HDN1-Q	MHD-36HRDN1-Q	MOU-36HDN1-Q	700W	3,0A	4800W	22,0A
MHD-42HRDN1-Q/MOU-42HDN1-Q	MHD-42HRDN1-Q	MOU-42HDN1-Q	1100W	5,0A	6300W	30,0A

Signature:

(Darius Guo)

Date, 2010-08-30

CBS 10 08 54647 828

Page 2 of 2



PSB Singapore